

2020 Annual Drinking Water Quality Report for

City of Frostproof WTP

System ID Number 6530627

This report will be mailed to each customer and is also available at 111 West First Street, Frostproof, FL 33843 upon request.

We're very pleased to provide you with this year's Annual Drinking Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source comes from three 12" wells that draw water from the Floridian Aquifer. Before delivery to you, the water is stripped of sulfides by cascading trays and then disinfected with chlorine.

In 2019 the Department of Environmental Protection performed a Source Water Assessment on our system. A search of the data sources indicated that there are only six potential sources of contamination near our wells and they have a low to high range susceptibility. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at www.dep.state.fl.us/swapp.

If you have any questions about this report or concerning your water utility, please contact **Jerry Wilbanks at 863-528-2184**. We encourage our valued customers to be informed about their water utility. Any customer can obtain additional information from EPA at their Safe Drinking Water Hotline (800-426-4791).

City of Frostproof WTP routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2020. Data obtained before January 1, 2020 and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

In the table below, you may find unfamiliar terms and abbreviations.

To help you better understand these terms we've provided the following definitions:

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Initial Distribution System Evaluation (IDSE): An important part of the Stage 2 Disinfection Byproducts Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below, which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or Micrograms per liter (µg/l): one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

Picocurie per liter (pCi/L): measure of the radioactivity in water.

Radioactive Contaminants Results in the Level Detected columns for ALL contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL Violation Y/N | Level Detected | Range of Results | MCL G | MCL | Likely Source of Contamination |
|---|---------------------------|-------------------|----------------|------------------|-------|-----|--------------------------------|
| Alpha emitters (pCi/L) | 1/20-12/20 | No | 7.7 | 4.6 – 7.7 | 0 | 15 | Erosion of natural deposits |
| Radium 226 + 228 or combined radium (pCi/L) | 1/20-12/20 | No | 2.5 | 0.8 – 2.5 | 0 | 5 | Erosion of natural deposits |

Inorganic Contaminants Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL Violation Y/N | Level Detected | Range of Results | MCL G | MCL | Likely Source of Contamination |
|-------------------------------------|---------------------------|-------------------|----------------|------------------|-------|-----|--|
| Nitrate (ppm) | 2/20 | N | 0.058 | 0.057 – 0.058 | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Barium (ppm) | 3/20 | N | 0.062 | 0.058 – 0.062 | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Fluoride (ppm) | 3/20 | N | 0.2 | 0.197 – 0.2 | 0 | 2.0 | Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm |
| Sodium (ppm) | 3/20 | N | 14.7 | 14.6 – 14.7 | N/A | 160 | Salt water intrusion, leaching from soil |

Stage 1 Disinfectants and Disinfection By-Products For bromate, chloramines, or chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.

| Disinfectant or Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL or MRDL Violation Y/N | Level Detected | Range of Results | MCLG or MRDLG | MCL or MRDL | Likely Source of Contamination |
|---|---------------------------|---------------------------|----------------|------------------|---------------|-------------|---|
| Chlorine (ppm) | 1/20 – 12/20 | N | 1.42 | .09 – 2.03 | MRDLG = 4 | MRDL = 4.0 | Water additive used to control microbes |

Stage 2 Disinfectants and Disinfection By-Products Haloacetic acids (five) (HAA5): Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. TTHM [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | MCL Violation (Y/N) | Level Detected | Range of Results | MCL G | MCL | Likely Source of Contamination |
|-------------------------------------|---------------------------|---------------------|----------------|------------------|-------|-----|---|
| Haloacetic Acids (HAA5) (ppb) | 3-20 / 10/20 | N | 46 | 22 - 46 | N/A | 60 | By-product of drinking water disinfection |
| Total Trihalomethanes (TTHM) (ppb) | 3-20 / 10/20 | N | 82 | 69 - 82 | N/A | 80 | By-product of drinking water disinfection |

Lead and Copper (Tap Water)

| Contaminant and Unit of Measurement | Dates of sampling (mo/yr) | AL Exceeded (Y/N) | 90th Percentile Result | No. of sampling sites exceeding the AL | MC LG | AL (Action Level) | Likely Source of Contamination |
|-------------------------------------|---------------------------|-------------------|------------------------|--|-------|-------------------|--|
| Copper (ppm) | 1/20 – 12/20 | N | 0.0514 | 0 | 1.3 | 1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead (ppb) | 1/20 – 12/20 | N | 0.0016 | 0 | 0 | 15 | Corrosion of household plumbing systems; erosion of natural deposits |

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Frostproof Water Treatment Plant is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [HTTP://www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In our continuing efforts to maintain a safe and dependable water supply, it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at City of Frostproof Water Treatment Plant work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

We at City of Frostproof Water Treatment Plant would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to insuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.